

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. CMO/HAT/2020/1485Date : 06/07/2020

It is certified that an inspection team headed by Dr. Devendra Kumar
Asst. CMO Hathras (Name of Officers
with designation) from CMO Office Hathras (Name of
Department/Office) inspected the Cambridge International
School, Mendu Road, Hathras (Name & Address of
the School) on 06/07/2020 and found that the Cambridge International
School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of _____.

Signature with Seal : [Signature] असल
Name : Dr. Devendra Kumar
Designation : Asst CMO, Hathras

To

manager - The Cambridge
International School, Ratangarhi
Mendu Road, Hathras

(Name & Address of the Institution)

[Signature]
Principal

The Cambridge International School
Ratangarhi Mendu Road Hathras

Kalpna
Manager

The Cambridge International School
Ratangarhi, Mendu Road, Hathras



U. P. JAL NIGAM

Water Testing Laboratory

राया रोड, ~~LEHRNA ROAD~~, HATHRAS

Water Analysis Report

Report No. 1

Dated 1-10-19

SI No. 4385

Source of Sampling- समर

Village - रतनगढ़ Code No.-

Name and Designation of Sample Collector- श्रीमती कल्पना उपाध्याय (प्रभारी) सहायक अभियंता

Date and Time of Sampling - 1-10-19

Date of obtaining Sample-

Date of Analysis- 1-10-19

Location of sample obtained- दाद रोड, रतनगढ़, हाथरस

(A) CHEMICAL ANALYSIS

	Unit	Test Results	Water quality Standard as per C.P.H.E.E.O. Manual	
			* Acceptable	** Causes for Rejection
1. PH Value		8.5	7.0 to 8.5	< 6.5 or > 9.2
2. Total Solids	--		200	2000
(i) Dissolved	mg/L	880		
(ii) Suspended Solid	"		--	--
3. Total Hardness (as CaCO ₃)	"	268	200	4000-6000
4. Alkalinity as CaCO ₃	"	760	200	600
(a) Phenolphtheline	"			
(b) Methyl Orange	"	53		
5. Chloride (as Cl)	"		200	1000
6. Iron	"	0.14	0.3	1.0
7. Nitrate	"	30	45	45
8. Fluorides as F	"	1.5	1.0	1.5
9. Sulphates (as So ₄)	"	168.8	200	400
10. Conductivity	micro mhos			

(B) PHYSICAL EXAMINATION

(a) Taste	Sl. 200	Unobjectionable	Unobjectionable
(b) Colour (Pt / Co Scale)	colourless	5	25
(c) Odour		Unobjectionable	Unobjectionable
(d) Turbidity	3.01 N.T.U.	2.5	10

Remark.....

[Lab Asstt.]

Junior Engineer

Counter Signed

ASSISTANT ENGINEER

Construction Division U.P. Jal Nigam, Hathras (U.P.)

NOTES :-

- * 1. The figures indicated under the column "Acceptable" are the limits upto which water is generally acceptable to the consumers.
- ** 2. Figures in excess of those Mentioned under "Acceptable" render the water not acceptable, but still may be tolerated in the absence of alternative and better source, but upto the limits indicated under column "Cause for rejection" above which the supply will have to be rejected.

प्राचार्य/Principal

केन्द्रीय विद्यालय/Kendriya Vidyalaya
बाद (मथुरा)/Baad (Mathura)

Manager

The Cambridge International School
Ratangarhi, Mendu Road, Hathras

PRINCIPAL
Sanskriti Public School
Baldev, Mathura (U.P.)
C.B.S.E. Aff. No. 2130334

Principal
The Cambridge International School
Ratangarhi Mendu Road Hathras